



NOTE

- 1 THIS DRAWING IS INDICATIVE AND TENDER PURPOSE ONLY. SUCCESSFUL TENDERER SHALL BE RESPONSIBLE FOR PREPARING THE DRAWING AS PER THE RULES OF LOCAL ELECTRICITY AUTHORITY, OBTAINING APPROVAL ON THE SAME AND EXECUTE THE WORK AS PER APPROVED DRAWING.
- 2 THE HEIGHT OF THE TWO/FOUR POLE STRUCTURES SHALL HAVE TO BE DESIGNED BASED ON THE REQUIRED CLEARANCE ABOVE GROUND OF 11KV CONDUCTOR AS PER INDIAN ELECTRICITY RULES/IS.
- 3 ALL STRUCTURAL STEEL MEMBERS SHALL BE PAINTED WITH TWO COATS OF RED OXIDE PRIMER AND TWO COATS OF ALUMINIUM FINISHING PAINT.
- 4 CT/PT CUBICLE & METERING UNIT TO BE SUPPLIED BY SEB.

TENDER PURPOSE ONLY



Balmer Lawrie & Co. Ltd.
ENGINEERING & PROJECTS

SCALE: 1:450				DATE 27.10.15				PROJECT: STANDARD DRAWING			
DRAWN				CHECKED				OWNER : BALMER LAWRIE & CO. LTD			
NO.				DATE				TITLE : 11 KV POWER RECEIVING SYSTEM			
REVISIONS				BY				APPROVED			
THIS DRAWING IS THE PROPERTY OF BALMER LAWRIE & CO. LTD. AND SHALL NOT BE DISCLOSED TO A THIRD PARTY COPIED OR USED WITHOUT THE WRITTEN CONSENT OF BALMER LAWRIE & CO. LTD.				APPROVED				JOB NO.			
				APPROVED				DRG.NO.BL/E&P/STD			
								SHT 1 OF 1 REV.0			